

**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE FOR OCCUPANCY**

From
The District Fire Officer,
O/o. State Disaster & Fire Service Dept.
Ranga Reddy Dist - TG

To
The Secretary
Global Institute of Engineering and
Technology, Chilkur (V) Moinabad (M)
Ranga Reddy - Dist - TG

Rc.No.1879/A1/Extn/2026: Dated:09-04-2026

Sir,

Sub: Telangana State Disaster Response & Fire Service Department-Central Region-I, Hyderabad-Issue of No Objection Certificate – Fire Safety measures to Non-Multi storied building (Educational Institute) Global Institute of Engineering and Technology, Chilkur (V) Moinabad (M) Ranga Reddy Dist – Issue of certificate for the academic year 2026-27 from the date of issue – Reg.

Ref: (1) Section 12(2) of Fire Service Act 1999 and rule 15(2) of TS Fire and Emergency Operations and levy of fee rules 2006.
(2) Chief Office Proceedings Rc.No.1738/2018 Dt.06-08-2018.
(3) Inspection dated 25-03-2026
(4) Application dated 10-02-2026 from Secretary, Global Institute of Engineering and Technology, chilkur (V) Moinabad (M) Ranga Reddy Dist-TG.

In obedience to the to the instructions issued by the Director of Fire Services, Hyderabad, Telangana – vide reference 2nd cited and in compliance to the authorities given in accordance with vide reference 2nd cited, as per the recommendation of Inspection team reported submitted vide reference 3rd cited, the fire safety measures to the non-multistoried building with height 9.45 mtrs for educational building with Ground+3 floors. Global Institute of Engineering and Technology , Chilkur (V) Moinabad (M) Ranga Reddy Dist-TG. are furnished here under: Particulars of building are as follows;

- a) Institution Name & Address: Global Institute of Engineering and Technology Chilkur (V) Moinabad (M) Ranga Reddy Deist.
- b) Area of Plot of building:2789.88 Sq.Mtrs.
- c) No of blocks Floors : Ground + 3 floors
- d) Floor wise details:

Sl.No.	Floor	Area in Sq,Mtrs	Occupancy (Educational Institution)	Occupation Load
1	Ground + 3 floors	2789.88 Sq.Mtrs	Educational B1	110
3	Total	11159.52 Sq.Mtrs	Educational B1	110

2. The Management has provided the following safety measures:

- a) Terrace Tank 5,000 liters capacity is provided and Booster pump 450 LPM.
- b) One Internal staircase width 2.70 mtrs provided.
- c) Two external staircase width of 1.25 mtrs each provided.
- d) Every room with a capacity of 40 students and above shall have at least doorways.

3. The following fire fighting's system are suggested:

- a) 8 (Eight) 12 liters water expelling extinguishers.
- b) 12 Five CO2 extinguishers of each 5 kg capacity for each floor.
- c) 10 (Ten) DCP extinguishers of each 5 kg capacity.
- d) 4 buckets 9 liters bottom fire buckets for each floor (2.buckets filled with water and two buckets filled with sand)for every 600 Sq. Mtrs built up area/floor should be hand to a stand.
- e) For every 600 sq.mtrs built up area/floor, the fire extinguishers should be located to be available within 25 mtrs radius.

4. The following No Objection certificate issued for a period of one year from the date of issue subject to the following conditions:

- a) All Fire Safety measures as advised should be provided without fail.
- b) No temporary structure as tents or thatched construction shall be allowed for Educational Institution.
- c) All the staff/watch and ward staff train in first aid fighting.

5. The Management may be informed of the following rules and regulations:

i) As per clause 13.1 of part II of, the National Building code of India neither granting of the Permit not the approval of drawings and specifications made by the authority during erection of the building shall in any way relieve the owner of such building from full reasonability for carrying out of the work in accordance with the requirements of the National Building Code of India.

ii) As per clause 8.3 of part II of the National Building Code of India "The licensed Architect/ Engineer/Structural Engineer/Supervisor/Town planner be responsible for supervision of the construction for the completion certificate. In the event of violation of provisions of the code be shall be liable to personalities as prescribed by the authority including cancellation of the license.

6. The management may advised to installation of above fire measurement and keep all fire Safety measures in good working condition at all times.

District Fire Officer
Ranga Reddy Dist
9/4/26.
DISTRICT FIRE OFFICER
RANGAREDDY - T.S.

(Handwritten initials)



Copy to submitted to the Director General of Fire and Emergency services, Hyd.
Copy submitted to the Regional Fire Officer, Ranga Reddy Deist.